

Mappa, Inc.

1956 Richardson Highway  
North Pole, AK 99705  
(907) 488-1266

Special Inspection Daily Report

Client: Eklotna Project: <sup>439</sup> EIE Fuel Mngmnt & Lab Facility

Test Date: 5/27/26 Test Time: 12pm Inspector: MJM

Contact: \_\_\_\_\_ Type of Inspection: Rebar

Time Charged to Project: Start Time: ~~11:30~~ End Time: ~~12:00~~ Total Hours Charged RT ~~0.5~~ OT \_\_\_\_\_

Inspections performed and locations

Location	Inspection Performed
Manhole Access Way Walls Sheet: S3 Detail: 1 Manhole	All Bar @ listed locations meets project specifications for type, sizing, spacing, counts, laps & clearances. All Bar is clean & free of deleterious materials.
Access Way Detail	Forms appear sturdy & well built to proper specifications. Forms are clean & free of debris
Manhole Lids Sheet: S2 Detail: 3	
Utiliduct Section	

Items requiring correction, correction of previously listed items and/or previously listed uncorrected items

N Wall S/26	All clearance issues corrected. No further corrections required.

Changes to approved plans authorized by engineer or architect of record (include paperwork)

	None

To the best of my knowledge, work inspected was in accordance with the approved plans and specifications

Signature: [Handwritten Signature] Printed Name: Markus Munk

2/2

# Mappa, Inc.

1956 Richardson Highway  
North Pole, AK 99705  
(907) 488-1266

## Special Inspection Daily Report

Client: Eklutna Project: <sup>439</sup> EIE Fuel Mngmt & Lab Facility

Test Date: 5/27/26 Test Time: 1pm Inspector: MSM

Contact: \_\_\_\_\_ Type of Inspection: Rebar

Time Charged to Project: Start Time 11:30 End Time 1:00 Total Hours Charged RT 2 OT \_\_\_\_\_

### Inspections performed and locations

Location	Inspection Performed
Utilidor Walls Dwg No. U01 Detail: Utilidor section	All Bar @ listed location meets project specifications for type, sizing, spacing, laps, counts & clearances. All Bar is clean & free of deleterious materials.
Utilidor Reinforcing Plan	Forms appear sturdy & well built to proper specifications. Forms are clean & free of debris.


### Items requiring correction, correction of previously listed items and/or previously listed uncorrected items

None

### Changes to approved plans authorized by engineer or architect of record (include paperwork)

None

To the best of my knowledge, work inspected was in accordance with the approved plans and specifications

Signature: 

Printed Name: Markus Black