

Mappa, Inc.

1956 Richardson Highway
North Pole, AK 99705
(907) 488-1266

Special Inspection Daily Report

Client: Eklutna

Project: FTW Front Gate

Test Date: 5/29

Test Time: 600

Inspector: MMW

Contact: _____

Type of Inspection: Placement

Time Charged to Project: Start Time 500 End Time 1200 Total Hours Charged RT 5 OT 2

Inspections performed and locations

Location	Inspection Performed
Center Lane Hard Stand Existing to 212ft N Lane Hardstand 215ft to 279ft	Observed placement of 126 cu yds of 253450I concrete, placed as per specifications @ listed locations. Consolidation was achieved by use of internal vibrator. All locations placed by chute. Placement began @ 618 am & was completed @ 1122 am. All tests taken @ middle 3rd of 1st, 6th & 11th trucks. Air & Slump taken @ 8th truck. Air alone @ 3rd truck. Test Results were w/in project requirements. See Field sheet for results

Items requiring correction, correction of previously listed items and/or previously listed uncorrected items

	<u>None</u>

Changes to approved plans authorized by engineer or architect of record (include paperwork)

	<u>None</u>

To the best of my knowledge, work inspected was in accordance with the approved plans and specifications

Signature: _____

Printed Name: Markus Mack

Client: Ekutra

Project:

FTW Front
gate

Date: 5/29

Weather

Partly Cloudy

Technicians: BM

Projected Shift CY = 130

Time Start: 6:10

Time End 11:22

Truck #	Ticket #	Air Content ASTM C231	Slump ASTM C143	Unit Weight ASTM C138	Temp ASTM C 1064	# Cyl ASTM C 39	Time Batch Time Pour	Water Added	Comments
1	108147	4.5	5 1/2	146.08	62°	9	532 618	—	Center Hard Stand Exist to 18ft
2	108148	—	—	—	—	—	554 638	+4gal	18ft to 38ft
3	108149	5.0	—	145.44	59°	—	619 652	—	38ft to 57ft
4	108151	—	—	—	—	—	644 720	+6gal	57ft to 78ft
5	108152	—	—	—	—	—	700 743	+4gal	78ft to 94ft
6	108153	5.2	5"	146.22	62°	9	723 800	—	94ft to 117ft
7	108154	—	—	—	—	—	737 823	—	117ft to 138ft
8	108155	5.8	6 1/2	144.66	62	—	756 838	+4gal	138ft to 154ft
9	108157	—	—	—	—	—	824 906	—	154ft to 175ft
10	108158	—	—	—	—	—	840 919	—	175ft to 197ft
11	108159	5.6	5 1/2	145.30	61°	9	856 941	+4gal	197ft to 212ft
12	108160	—	—	—	—	—	913 1003	—	N Lane Hard Stand 215ft to 234ft
13	108161	—	—	—	—	—	957 1020	+3gal	234ft to 261ft
14	108162	—	—	—	—	—	1033 1115	—	261ft to 279ft