



**ASTM D6938 In-Place Density and Water Content of Soil and
Soil-Aggregate by Nuclear Methods (Shallow Depth)****Project: Veterans Salcha Cemetary**
Salcha, AK
Client: H.C. Contractor**Project #: 2026-012**
Date: July 16, 2026
Area Tested: See map for locations**Material / Source:**
Pitrun/ Rolling Stone 146.6
Unclassified fill**Gauge: Instron 3500**
Operator: Paul Gerber
Ser: # 1408

Test #	Soil Type	Test Depth(in)	Lift Elev	Location	Wet Density	% Moist.	Dry Density	Max Density	Percent Density	Required Density
1	pitrun	8"	L1	See map for location Map #1	148.2	5.0	141.1	146.6	96.3%	95%
2	pitrun	8"	L1	See map for location Map #1	146.5	5.2	139.3	146.6	95.0%	95%
3	pitrun	8"	L1	See map for location Map #1	146.6	4.9	139.8	146.6	95.3%	95%
4	pitrun	8"	L1	See map for location Map #1	147.6	5.2	140.3	146.6	95.7%	95%
5	UC	8"	Top Trench	See map for locations map #2 Electric Trench	147.9	6.2	139.3	146.6	95.0%	95%
6	UC	8"	Top Trench	See map for locations map #2 Electric Trench	149.3	6.9	139.7	146.6	95.3%	95%
7	pitrun	8"	L1	See map for locations map #2 Electric Trench	147.8	4.7	141.2	146.6	96.3%	95%
8	pitrun	8"	845.5 top trench	See map for locations map #2 Electric Trench	153.3	5.7	145.0	146.6	98.9%	95%

Map # 1



ADMINISTRATION BUILDING ENLARGEMENT
SCALE 1/8" = 1'-0"



ADMINISTRATION BUILDING SIDEWALK PAVEMENT DETAIL
SCALE 1/8" = 1'-0"

REFERENCE NOTES SCHEDULE

CODE	DESCRIPTION	DETAIL
10	TRANSPIRENT VINE RECEPTACLE WITH OVER WATERING STATION, SEE L.S. DETAIL 1	
11	ORNAMENTAL FENCE, SEE L.S. DETAIL 2 & 3	
14	ORNAMENTAL GATE, SEE L.S. DETAIL 4 & 5	
16	WALKWAY SIGN, SEE L.S. DETAIL 6	
17	ORNAMENTAL FENCE, SEE L.S. DETAIL 7	
37	SHOW STORAGE AREA	

H.C. VET Cemetery
7-16-24



DATE	NOTE

DESIGNED BY
BUREAU OF LAND MANAGEMENT
U.S. DEPARTMENT OF THE INTERIOR

DEPARTMENT OF TRANSPORTATION AND
PUBLIC UTILITIES

DEPARTMENT OF MILITARY AND
VETERANS AFFAIRS



INTERIOR ALASKA VETERANS
CEMETERY (IAVC)
ADMINISTRATIVE PROJECT NO. 100-10000
ADMINISTRATION BUILDING
ENLARGEMENTS

SHEET NO.	13
OF 14	14

DATE	7/24/24
BY	LS 405
CHECKED BY	LS 405
APPROVED BY	LS 405

12/12/2020 2:21:57 PM



H.C. Vet Cemetery 7-16-26