

Special Inspection Daily Report

Client: Cornerstone Project: FTW 405
Test Date: 06/21/26 Test Time: _____ Inspector: John Trush
Contact: JAICE Type of Inspection: Reinforcing Steel
Time Charged to Project: Start Time 9 End Time 930 Total Hours Charged RT 1 OT _____

Inspections performed and locations

Location	Inspection Performed
Enclosed bleachers stoops by 3 side apron	Inspection of reinforcing steel was performed at listed locations. Reinforcing bars inspected were the correct sizes, shapes, type, in clean condition and placed in forms free of debris. Forms were constructed of approved material and securely shored to hold shape. Inspected reinforcing steel appeared installed in accordance with approved contract documents for spacing, clearance and lapsplice. Please reference sheet S-501 Door/Apron Detail Drawing NO. 05 Thickend Edge Reinforce 3-Each

Items requiring correction, correction of previously listed items and/or previously listed uncorrected items

	<u>NONE</u>

Changes to approved plans authorized by engineer or architect of record (include paperwork)

	<u>NONE</u>

To the best of my knowledge, work inspected was in accordance with the approved plans and specifications

Signature:  Printed Name: John R. Trush CET